CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1501:140 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Edwards, 90 Fieldstone Ct., Cheshire, CT 06410

Contact: David Mazur (203) 699-3155

DESIGN: Models 97DEXC-GW, 97DEXBC-GW and 97DEXCC-GW signal lights. Unit is intended for

> use in Class I, Groups C and D; Class II, Groups E, F and G; and Class III hazardous areas. Refer to listee's data sheet for additional detailed product description and operational

considerations.

RATING: Electrical: 24-28 VDC, 1.4A

> Candela: 15 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as signal lights for use with separately listed compatible fire alarm control units.

Suitable for the hearing impaired applications and hazardous location as described under

"Design". For indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. the appliance must be used with a fire alarm control unit that can generate the temporal

pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7125-1388:210

02-27-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

FEBRUARY 27, 2003 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager